

தடையின்மைச் சான்று


கோயம்பேடு தீயணைப்பு-மீட்புப்பணிகள் நிலையம்

வ.எண்: 04/2022

எண் :16/V/2022

நாள் :12.01.2022

பொருள் : தீயணைப்பு - மீட்புப்பணித்துறை- கோயம்பேடு தீயணைப்பு -
நிலையம் - பள்ளிக்கூடம் நிறுவலி/அங்கீகாரம் வழங்கிடதடையின்மைச் சான்றுவழங்குதல் -



சென்னை-600 107
தேதி: 12.01.2022
1. அரசாணை எண்.122 பள்ளிகல்வி (2) துறை,நாள் 14.09.2004
2. அரசாணை எண்.123 பள்ளிகல்வி (2) துறை,நாள் 14.09.2004
3. THE CORRESPONDENT, பெறப்பட்ட விண்ணப்பம் நாள் 10.01.2022.

காணும் அரசாணை மற்றும் விண்ணப்பத்தின்படி கதவு இலக்கம் எண்:-


NO. 127, P.H. ROAD, NERKUNDRAM, CHENNAI 107, என்றமுகவரியில்

நிறுவப்பட்டுள்ள M/S: DAYASADAN AGARVAL VIDYALAYA., என்ற பள்ளியினை 11.01.2022 அன்று கோயம்பேடு நிலைய அலுவலர் திரு. எஸ்.ராஜேந்திரன் என்பவரால் ஆய்வுசெய்யப்பட்டது. இவ்விடத்தில் பள்ளிக்கூடம் நிறுவலி / அங்கீகாரம் வழங்கிட கீழ்க்காணும் நிபந்தனைகளுக்கு உட்பட்டு தீயணைப்பு மற்றும் மீட்புப்பணி நோக்கிலிருந்து யாதொரு தடையும் இல்லை.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this dept.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 people per Sq. metre as per The National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.

பெறுநர்


தீயணைப்பு-மீட்பு பணிகள் நிலையம்
கோயம்பேடு, சென்னை-600 107.

M/S:THE CORRESPONDENT,
DAYASADAN AGARWAL VIDYALAYA.,
NO:127, P.H. ROAD,
NERKUNDRAM, CHENNAI 107.

நகல்: மாவட்ட அலுவலர், மத்திய சென்னை மாவட்டம்.

FIRE SAFETY CERTIFICATEDated : 12 .01.2022

Certified that **DAYASADAN AGARWAL VIDYALAYA, No. 127, P.H. Road, Nerkundram, Chennai – 600 107**, Comprised of stilt Ground + 2 Upper floors owned / occupied by **DAYASADAN AGARWAL VIDYALAYA**, have complied with the fire prevention and fire safety requirements in accordance with the rule of State/UT Fire Service Rules, and verified by the officers of **Fire & Rescue Department** on **11.01.2022** by **Mr. S. RAJENDRAN** that the building / premises is fit for occupancy for students valid for a period of 1 year in accordance with the rule and subject to compliance of the conditions.

Issued on 12.01.2022 at Koyambedu - **Fire & Rescue Department** by

Signature with Seal: sd/.....

Name: **Mr. S. RAJENDRAN**

Designation: Inspector

To
THE CORRESPONDENT
DAYASADAN AGARWAL VIDYALAYA,
 No.127, P.H. ROAD,
 NERKUNDRAM,
 CHENNAI - 600 107.



[TRUE TRANSLATION FROM
 Tamil to English]

V.K. Saithe Kumar
 18/1/2022
V.K. SAITHE KUMAR, B.A., B.L.,
ADVOCATE & NOTARY PUBLIC
 Reg. No. 9, Kottur High Road,
 5th Lang, Ayeravaram,
 Chennai-600 029. Enroll No: 330/85
 Cell: 9510914759